



Building Partnerships for Tomorrow

Union County Educational Services Commission

45 Cardinal Drive
Westfield, New Jersey 07090
Phone: 908-233-9317
Fax: 908-233-7432
Transportation Fax: 908-518-1669

Carrie Dattilo
Acting Superintendent
cdattilo@ucesc.org

Eric Larson
Business Administrator/
Board Secretary
elarson@ucesc.org

Lorraine Vitiello
Transportation Coordinator
lvitiello@ucesc.org

To whom it may concern:

On Tuesday April 23, 2022, Union County Educational Services Commission conducted lead in drinking water sampling at their following facilities: Hillcrest Academy North, Crossroads School and Holy Spirit. The lead in drinking water sampling was conducted in accordance with the New Jersey Schools Lead in Drinking Water Regulations; N.J.A.C. 6A:26-1.2;12.4 and the USEPA "3 T's for Reducing Lead in Drinking Water in Schools". A total of one hundred and fifty-four (154) drinking water samples were taken from all drinking water outlets to which a student or staff member has or may have access to in the above listed Union County Educational Services Commission .

Of the 154 samples taken, all but eleven (11) tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]). In compliance with N.J.A.C. 6A:26-1.2;12.4 twenty-four-hour notification requirements to the Department of Education the table below identifies the water outlets that tested above the 15 ppb for lead, the actual lead level, and what temporary immediate remedial action Union County Educational Services Commission reduce the levels of lead at these locations.

Sample Location	Initial Results in µg/l (ppb)	Flush Results in µg/l (ppb)	Remedial Action
Crossroads Point-of-Entry ID # CR-POE	31820	278.4	Posted as "Do Not Drink-Safe for Handwashing Only"
Hillcrest North Point-of-Entry ID # HN-POE	113.3	ND	Posted as "Do Not Drink-Safe for Handwashing Only"
Holy Spirit 1 st Floor Ladies Bathroom ID#HS-S-04	75.30	3.550	Posted as "Do Not Drink-Safe for Handwashing Only"
Holy Spirit Room 109 ID#HS-WF-08	209.0	68.36	Disconnected outlet and bottled water provided
Holy Spirit Room 104 ID#HS-WF-11	16.96	5.525	Disconnected outlet and bottled water provided
Holy Spirit Room 101 ID# HS-S-12	24.57	1.695	Posted as "Do Not Drink-Safe for Handwashing Only"
Holy Spirit	17.35	4.407	Disconnected outlet and bottled

Union County Educational Services Commission

www.ucesc.org



Building Partnerships for Tomorrow

Union County Educational Services Commission

45 Cardinal Drive

Westfield, New Jersey 07090

Phone: 908-233-9317

Fax: 908-233-7432

Transportation Fax: 908-518-1669

Carrie Dattilo
Acting Superintendent
cdattilo@ucesc.org

Eric Larson
Business Administrator/
Board Secretary
elarson@ucesc.org

Lorraine Vitiello
Transportation Coordinator
lvitiello@ucesc.org

Sample Location	Initial Results in $\mu\text{g/l}$ (ppb)	Flush Results in $\mu\text{g/l}$ (ppb)	Remedial Action
Room 101 ID# HS-WF-13			water provided
Holy Spirit 2 nd Floor Ladies Bathroom ID# HS-S-18	188.9	3.163	Posted as "Do Not Drink-Safe for Handwashing Only"
Holy Spirit 2 nd Floor Men's Bathroom ID# HS-S-22	63.89	2.455	Posted as "Do Not Drink-Safe for Handwashing Only"

Superintendent Name (Print):

Signature:

Carrie Dattilo

Date:

6/6/2022